MANITOWOC COUNTY HEALTH DEPARTMENT
Environmental Health
1028 S. 9th Street
Manitowoc, WI 54220
(920) 683-4155

STATE OF WISCONSIN

Recreational Educational Camp Inspection Report

Establishment Information	
Facility Name CUB SCOUT WORLD - CAMP ROKILIO	Facility Type Recreational/Educational Camp - Moderate
Facility ID # HSAT-7QWGN8	Facility Telephone # 920 894-2594
Facility Address	
Licensee Name BAY-LAKES COUNCIL BSA	Licensee Address PO BOX 267 APPLETON, WI 54912

Inspection Information		
Inspection Type Routine	Inspection Date June 15, 2026	Total Time Spent

Equipment Temperatures	
Description ice cream freezers - trading post	Temperature (Fahrenheit) frozen solid

Food Temperatures	
Description	Temperature (Fahrenheit)
frozen foods	frozen solid

Warewashing Info					
Machine Name	**Sanitization Method**	**Thermo Label**	**PPM**	**Sanitizer Name**	**Sanitizer Type**
3 comp sink in trading post	chemical		2.11	Ecolab Sink and Surface	Lactic acid

Certified Manager		
Name	Certificate #	Certificate Expiration
TICK HAYES		6/2/2030
HANSEL ANDERSON	29299861	6/13/2031

OPERATOR - The violations in operating procedure or physical arrangement indicated below must be corrected by the next routine inspection or by a date specified in this report.

Observed Violations

Total # 3

Good Retail Practices - 38 - Insects, rodents & animals not present,/outer openings protected
REPEAT OBSERVATION: The exterior door on trading post is not self-closing.
CORRECTIVE ACTION(S): Provide a self-closing and tight fitting door to prevent the entrance of insects or rodents.
Correct By: 31-Jul-2026

CODE CITATION: 6-202.15 (A) Except as specified in ¶¶ (B), (C), (D), and (E) of this section, outer openings of a FOOD ESTABLISHMENT shall be protected against the entry of insects and rodents by:
(3) Solid, self−closing, tight−fitting doors.

Water Supply - 10R - Plumbing system constructed and maintained
OBSERVATION: The handwash sink basin drain at staff cabin was not draining properly. Through conversations with the camp staff it has been determined that plumbing work was done in the dining hall without the oversight of a master plumber. In commercial buildings such as at Camp Rokilio all plumbing work must be done by a Master Plumber if it involves the installation, repair or replacement of water and wastelines. Informational handouts are enclosed regarding plumbing laws in Wisconsin.
CORRECTIVE ACTION(S): Repair/unclog the drain line so that it drains correctly. Contact a master plumber to inspect any work that may have been done by staff that needed a master plumber's license. Have the master plumber make any necessary repairs and provide documentation to the Manitowoc County Health Dept. Correct By: 26-Jun-2026
CODE CITATION: ATCP 78.18 (3) (a) General. All plumbing shall comply with the requirements of chs. SPS 382 and 384, as enforced by the Wisconsin department of safety and professional services, that apply to camps.

Buildings and Grounds - 28R - Building code; handrails, guards, and stairs
OBSERVATION: One of the guards on the upper walk way at the Castle had pulled out of the wall anchors and had warp severely,
CORRECTIVE ACTION(S): Repair the damaged guard to code. Staff caution taped off/closed the affected area until the repair could be made. The Ranger needed to rent a hammer drill to make the repair. Send photo of repair to MCHD when finished. Correct By: 26-Jun-2026
CODE CITATION: ATCP 78.24 (1) WISCONSIN BUILDING CODE. Except as specified in this section, all buildings at a camp shall comply with applicable Wisconsin department of safety and professional services standards as enforced by the Wisconsin department of safety and professional services.

Comments:

Any operator aggrieved by an order of this department under this chapter may request a hearing as provided in ch.227 statute, if state licensed, or a local ordinance if licensed by an agent health department.

Person in Charge



DAN SKRYPCZAK

Sanitarian



Jessica Wanserski
(920) 683-4454